


CENTRAL POWER RESEARCH INSTITUTE
(Member of STL)



CPRI

TEST REPORT

Test Report Number	SC13498A	Dated: 3 rd September, 2013
Name & Address of the Customer	M/s. Matulya Sales Corporation, Anand Villa, 13-Kalyan Nagar-6, Tonk Road, Jaipur – 302 011.	
Name & Address of the Manufacturer	M/s. Matulya Sales Corporation, Anand Villa, 13-Kalyan Nagar-6, Tonk Road, Jaipur – 302 011.	
Particulars of sample tested	GI Earthing Electrode	
Condition of the sample on Receipt	New	
Type	Pipe in Pipe technology	
Designation	GI Pipe GI Strip Earthing Electrode	
Serial Number(s)	---	
Number of samples tested	One	
Date (s) of test (s)	2 nd September, 2013	
CPRI sample code no(s).	SC13S1836	
Particulars of tests conducted	Short-time withstand current	
Test in accordance with	Customer's instruction	
Standard / specification	Not applicable	
Sampling plan	15 kA rms for 1.0 s with 37.5 kA peak	
Customer's requirement	---	
Deviations if any	---	
Name of the witnessing persons		
Customer's representative	Mr. Giriraj, Manager	
Other than customer's representative	None	
Test subcontracted with address of the laboratory	None	
Documents constituting this report (In words)		
Number of sheets	Four	
Number of oscillograms	One	
Number of graphs	Nil	
Number of photos	Three	
Number of test circuit diagrams	One	
Number of drawings	One	


(H.S. Lokeshappa)
Test Engineer




(Swaraj Kumar Das)
Joint Director